

## Lake Huron Primary Water Supply System – 2022 1<sup>st</sup> Quarter Water Quality Report

There were no adverse test results for the Lake Huron Primary Water Supply System during this quarter.

### List of Acronyms:

MAC – Maximum Acceptable Concentration; as identified in O.Reg. 169 (Ontario Drinking-Water Quality Standards)

IMAC - Interim Maximum Acceptable Concentration; as identified in the Technical Support Document for Ontario Drinking Water Standards, Objectives and Guidelines

AO/OG – Aesthetic Objective/Operational Guideline; as identified in the Technical Support Document for Ontario Drinking Water Standards, Objectives and Guidelines

NT – Not Tested

NR – Not Required

ND – Not Detected

**Analytical Test Results: (All values are reported in mg/L unless otherwise noted; All results are for treated water leaving the Water Treatment Plant unless otherwise noted)**

### Microbiological Parameters (Required Testing Under O.Reg. 170/03):

Microbiological Parameter	MAC or IMAC	No. of Samples	No. of Detectable Results	No. of Adverse Results	Method	Sampling Date	Min. Result	Max. Result	Comments
Total Coliform (counts/100ml) <sup>i</sup>	Not Detectable	63	0	0	Membrane Filtration	Jan-Mar	0	0	Parameter sampled is used to test for the possible presence of fecal matter. Zero detectable test results indicates that Total Coliforms were not detected.
E. coli (counts/100ml) <sup>ii</sup>	Not Detectable	63	0	0	Membrane Filtration	Jan-Mar	0	0	Parameter sampled is used to test for the possible presence of fecal matter. Zero detectable test results indicates that E.coli was not detected.
Heterotrophic Plate Count (counts/1ml)	N/A	63	7	0	Spread Plate Count	Jan-Mar	<10	60	Test parameter is used as an indicator of possible deterioration of water quality. Increases in HPC concentrations above baseline levels are considered undesirable.

## Operational Parameters:

Operational Parameter	MAC or IMAC	Objective AO/OG	No. of Samples	Sampling Date	Min. Result	Max. Result	Avg. Result	Comments
Chlorine Residual, Free (mg/L) <sup>iii</sup>			Continuous monitoring plus 6 grab samples per day	Jan-Mar	1.00	1.71	1.40	The maintenance of an adequate free chlorine residual is essential to the protection of public health. Values reported are based on the 6 daily grab samples. The regulated minimum for free chlorine residual concentration in a water distribution system is 0.05mg/L; however the contractual obligation of the water system is to achieve 0.5mg/L at the point of supply to the municipalities.
Chlorine Residual, Total (mg/L)			Continuous monitoring plus 6 grab samples per day	Jan-Mar	1.02	1.89	1.55	The maintenance of an adequate free chlorine residual in essential to the protection of public health. Values reported are based on the 6 daily grab samples.
Colour (TCU)		5	2 grab samples per day	Jan-Mar	<3	<3	<3	Values reported are based on the 2 daily grab samples.
Conductivity (µS/cm)			Continuous monitoring plus 2 grab samples per day	Jan-Mar	194	259	217	Values reported based on daily minimum, maximum and average that have been recorded electronically.
pH (no units)		6.5 – 8.5	Continuous monitoring plus 6 grab samples per day	Jan-Mar	6.72	8.66	8.00	Values reported are based on the 6 daily grab samples.
Turbidity (NTU) <sup>iv v</sup>			Continuous monitoring plus 6 grab samples per day	Jan-Mar	0.019	0.127	0.051	Turbidity (cloudiness) of water is an indication of the presence of particles in the water. If excessive, it may interfere with proper disinfection. Values reported are based on the 6 daily grab samples.

Operational Parameter	MAC or IMAC	Objective AO/OG	No. of Samples	Sampling Date	Min. Result	Max. Result	Avg. Result	Comments
Aluminum (mg/L)		< 0.1	2 grab samples per day	Jan-Mar	0.006	0.054	0.021	Aluminum levels are slightly elevated during treatment as a result of the use of alum to help in the removal of particulates.
Temperature (Celsius)		15	Continuous monitoring plus 6 grab samples per day	Jan-Mar	1.9	6.0	2.9	Raw Water Temperature. Values reported are based on the 6 daily grab samples.

**Inorganic Parameters (Required Testing Under O.Reg. 170/03 – Schedule 23):**

Schedule 23 - Inorganic Parameter	MAC or IMAC (mg/L)	Objective AO/OG	O.Reg. 170/03 Required Frequency of Testing (months)	Q2 2021	Q3 2021	Q4 2021	Q1 2022	Reportable Detection Limit (mg/L)	Comments
Antimony	0.006		12	NT	NT	NT	ND	0.0009	
Arsenic	0.010		12	NT	NT	NT	ND	0.0002	
Barium	1.0		12	NT	NT	NT	0.0135	0.00002	
Boron	5.0		12	NT	NT	NT	0.013	0.002	
Cadmium	0.005		12	NT	NT	NT	0.000003	0.000003	
Chromium	0.05		12	NT	NT	NT	0.00022	0.00008	
Mercury	0.001		12	NT	NT	NT	ND	0.00001	
Selenium	0.05		12	NT	NT	NT	0.00012	0.00004	
Uranium	0.02		12	NT	NT	NT	0.000045	0.000002	

**Organic Parameters (Required Testing Under O.Reg. 170/03 – Schedule 24):**

Schedule 24 – Organic Parameters	MAC or IMAC (mg/L)	Objective AO/OG	O.Reg. 170/03 Required Frequency of Testing (months)	Q2 2021	Q3 2021	Q4 2021	Q1 2022	Reportable Detection Limit (mg/L)	Comments
Alachlor	0.005		12	NT	NT	NT	ND	0.00002	Herbicide
Atrazine + N-dealkylated metabolites	0.005		12	NT	NT	NT	0.00003	0.00001	Herbicide
Azinphos-methyl	0.02		12	NT	NT	NT	ND	0.00005	Insecticide
Benzene	0.005		12	NT	NT	NT	ND	0.00032	An aromatic hydrocarbon present in gasoline
Benzo(a)pyrene	0.00001		12	NT	NT	NT	ND	0.000004	A polycyclic aromatic hydrocarbon (PAH) that forms during the combustion of organic matter (e.g. emissions from burning fossil fuels)
Bromoxynil	0.005		12	NT	NT	NT	ND	0.00033	Herbicide
Carbaryl	0.09		12	NT	NT	NT	ND	0.00005	Insecticide
Carbofuran	0.09		12	NT	NT	NT	ND	0.00001	Insecticide
Carbon Tetrachloride	0.005		12	NT	NT	NT	ND	0.00017	An organic liquid that is primarily released from man-made sources; used in industrial and agricultural process
Chlorpyrifos	0.09		12	NT	NT	NT	ND	0.00002	Pesticide
Diazinon	0.02		12	NT	NT	NT	ND	0.00002	Insecticide
Dicamba	0.12		12	NT	NT	NT	ND	0.0002	Herbicide

Schedule 24 – Organic Parameters	MAC or IMAC (mg/L)	Objective AO/OG	O.Reg. 170/03 Required Frequency of Testing (months)	Q2 2021	Q3 2021	Q4 2021	Q1 2022	Reportable Detection Limit (mg/L)	Comments
1,2-Dichlorobenzene	0.2	0.003	12	NT	NT	NT	ND	0.00041	An organic compound used in both industrial and commercial products (coolant, degreaser, solvent)
1,4-Dichlorobenzene	0.005	0.001	12	NT	NT	NT	ND	0.00036	An organic compound used in both industrial and commercial products (deodorizer, fungicide, lubricant)
1,2-Dichloroethane	0.005		12	NT	NT	NT	ND	0.00035	An organic chemical with many industrial and commercial applications (solvent, fumigant, ingredient in plastics etc.)
1,1-Dichloroethylene (vinylidene chloride)	0.014		12	NT	NT	NT	ND	0.00033	Volatile organic compound; imported for use in the food packaging and textile industries
Dichloromethane (Methylene Chloride)	0.05		12	NT	NT	NT	ND	0.00035	Volatile organic compound used in a variety of industries (electronics, textiles, pharmaceuticals, plastics etc.)
2,4-Dichlorophenol	0.9	0.0003	12	NT	NT	NT	ND	0.00015	An organic compound used in industry and chemical manufacturing
2,4-Dichlorophenoxy acetic acid (2,4-D)	0.1		12	NT	NT	NT	ND	0.00019	Herbicide
Diclofop-methyl	0.009		12	NT	NT	NT	ND	0.0004	Herbicide
Dimethoate	0.02		12	NT	NT	NT	ND	0.00006	Insecticide

Schedule 24 – Organic Parameters	MAC or IMAC (mg/L)	Objective AO/OG	O.Reg. 170/03 Required Frequency of Testing (months)	Q2 2021	Q3 2021	Q4 2021	Q1 2022	Reportable Detection Limit (mg/L)	Comments
Diquat	0.07		12	NT	NT	NT	ND	0.001	Herbicide
Diuron	0.15		12	NT	NT	NT	ND	0.00003	Herbicide
Glyphosate	0.28		12	NT	NT	NT	ND	0.001	Herbicide
Malathion	0.19		12	NT	NT	NT	ND	0.00002	Insecticide
2 methyl-4-chlorophenoxyacetic acid (MCPA)	0.1		12	NT	NT	NT	ND	0.00012	Herbicide
Metolachlor	0.05		12	NT	NT	NT	ND	0.00001	Herbicide
Metribuzin	0.08		12	NT	NT	NT	ND	0.00002	Herbicide
Monochlorobenzene	0.08	0.03	12	NT	NT	NT	ND	0.0003	A man-made organic compound; primarily used as a solvent
Paraquat	0.01		12	NT	NT	NT	ND	0.001	Herbicide
Pentachlorophenol	0.06		12	NT	NT	NT	ND	0.00015	An organic compound; used as a pesticide and wood preservative (manufacture and use banned since the 1980's)
Phorate	0.002		12	NT	NT	NT	ND	0.00001	Insecticide
Picloram	0.19		12	NT	NT	NT	ND	0.001	Herbicide
Polychlorinated Biphenyls (PCB)	0.003		12	NT	NT	NT	ND	0.00004	An organic compound; used in electrical equipment and as a fire retardant (use has been banned since the 1980's)

Schedule 24 – Organic Parameters	MAC or IMAC (mg/L)	Objective AO/OG	O.Reg. 170/03 Required Frequency of Testing (months)	Q2 2021	Q3 2021	Q4 2021	Q1 2022	Reportable Detection Limit (mg/L)	Comments
Prometryne	0.001		12	NT	NT	NT	ND	0.00003	Herbicide
Simazine	0.01		12	NT	NT	NT	ND	0.00001	Herbicide
Terbufos	0.001		12	NT	NT	NT	ND	0.00001	Insecticide
Tetrachloroethylene (perchloroethylene)	0.01		12	NT	NT	NT	ND	0.00035	An organic compound; used as a solvent in dry cleaning and metal cleaning industries
2,3,4,6-Tetrachlorophenol	0.10	0.001	12	NT	NT	NT	ND	0.0002	An organic compound; currently used mainly as a wood preservative
Triallate	0.23		12	NT	NT	NT	ND	0.00001	Herbicide
Trichloroethylene	0.05		12	NT	NT	NT	ND	0.00044	Volatile organic compound; used in metal degreasing operations and chemical manufacturing
2,4,6-Trichlorophenol	0.005	0.002	12	NT	NT	NT	ND	0.00025	Volatile organic compound; used in the manufacture of pesticides
Trifluralin	0.045		12	NT	NT	NT	ND	0.00002	Herbicide
Vinyl Chloride	0.002		12	NT	NT	NT	ND	0.00017	Volatile organic compound; Used in making PVC (polyvinyl chloride) plastic items



**Additional Organic Parameters (Removed from Schedule 24 as of January 1, 2016)**

Organic Parameter	MAC or IMAC (mg/L)	Objective AO/OG	Required Frequency of Testing (months)	Q2 2021	Q3 2021	Q4 2021	Q1 2022	Reportable Detection Limit (mg/L)	Comments
Aldicarb			NR	NT	NT	NT	ND	0.00001	Insecticide
Aldrin + Dieldrin			NR	NT	NT	NT	ND	0.00001	Insecticide
Bendiocarb			NR	NT	NT	NT	ND	0.00001	Insecticide
Chlordane (total)			NR	NT	NT	NT	ND	0.00001	Pesticide
Cyanazine			NR	NT	NT	NT	ND	0.00003	Herbicide
Dichlorodiphenyltrichloroethane (DDT) + metabolites			NR	NT	NT	NT	ND	0.00001	Insecticide
Dinoseb			NR	NT	NT	NT	ND	0.00036	Insecticide, Herbicide
Heptachlor + Heptachlor Epoxide			NR	NT	NT	NT	ND	0.00001	Insecticide
Lindane (Total)			NR	NT	NT	NT	ND	0.00001	Pesticide
Methoxychlor			NR	NT	NT	NT	ND	0.00001	Insecticide
Parathion			NR	NT	NT	NT	ND	0.00002	Insecticide
Temephos			NR	NT	NT	NT	ND	0.00001	Insecticide
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)			NR	NT	NT	NT	ND	0.00022	Herbicide

## General Chemistry and Physical Parameters (Additional Regulatory and Contractual Testing)

General Chemistry or Physical Parameter	MAC or IMAC (mg/L)	Objective AO/OG (mg/L)	O.Reg. 170/03 Required Frequency of Testing (months)	Contractual Required Frequency of Testing (months)	Q2 2021	Q3 2021	Q4 2021	Q1 2022	Reportable Detection Limit (mg/L)	Comments
Alkalinity (Total as CaCO <sub>3</sub> )		30 – 500	NR	6	84	78	81	86	2	Q1 value is based on 4 sample results
Calcium			NR	12	NT	NT	NT	26.2	0.01	
Chloride		250	NR	12	NT	NT	NT	9.8	0.04	
Copper		1.0	NR	12	NT	NT	NT	0.0006	0.0002	
Dissolved Organic Carbon (mg/L as C)		5	NR	12	1.6	8.1	1.3	1.3	1	Q1 value is based on 4 sample results
Dissolved Inorganic Carbon (mg/L as C)			NR	6	0.024	0.021	0.019	0.019	1	
Ethylbenzene	0.14	0.0016	NR	12	NT	NT	NT	ND	0.00033	
Fluoride	1.5		60	NA	NT	NT	NT	ND	0.06	
Geosmin (ng/L)		4.0	NR	Weekly as Required	ND	0.3	ND	ND	3.0 ng/L	Geosmin is tested weekly from July 1-Oct 31. Results are expressed as the average per quarter when testing is required.
Haloacetic Acids (Arva Reservoir)	0.08	0.060	3	3	0.0057	0.0072	0.0158	ND	0.0053	The standard is expressed as a running annual average of quarterly samples measured at a point reflecting the maximum residence time in the distribution system. Running annual average: 0.0072 mg/L

General Chemistry or Physical Parameter	MAC or IMAC (mg/L)	Objective AO/OG (mg/L)	O.Reg. 170/03 Required Frequency of Testing (months)	Contractual Required Frequency of Testing (months)	Q2 2021	Q3 2021	Q4 2021	Q1 2022	Reportable Detection Limit (mg/L)	Comments
Haloacetic Acids (Exeter-Hensall)	0.08	0.060	3	3	0.0186	0.0163	0.0100	0.0141	0.0053	The standard is expressed as a running annual average of quarterly samples measured at a point reflecting the maximum residence time in the distribution system. Running annual average: 0.0148 mg/L
Haloacetic Acids (Komoka-Mt. Brydges)	0.08	0.060	3	3	0.0122	0.0148	0.0076	0.0122	0.0053	The standard is expressed as a running annual average of quarterly samples measured at a point reflecting the maximum residence time in the Running annual average: 0.0117 mg/L
Haloacetic Acids (Strathroy-Caradoc)	0.08	0.060	3	3	0.0060	0.0077	0.0163	0.0055	0.0053	The standard is expressed as a running annual average of quarterly samples measured at a point reflecting the maximum residence time in the distribution system. Running annual average: 0.0089 mg/L
Hardness (mg/L as CaCO <sub>3</sub> )		80 – 100	NR	12	NT	NT	NT	95.2	0.05	
Iron		0.30	NR	12	NT	NT	NT	ND	0.007	

General Chemistry or Physical Parameter	MAC or IMAC (mg/L)	Objective AO/OG (mg/L)	O.Reg. 170/03 Required Frequency of Testing (months)	Contractual Required Frequency of Testing (months)	Q2 2021	Q3 2021	Q4 2021	Q1 2022	Reportable Detection Limit (mg/L)	Comments
Lead	0.01		NR	6	0.00005	0.00010	0.00001	0.00012	0.00001	
Magnesium			NR	12	NT	NT	NT	7.21	0.001	
Manganese		0.05	NR	12	NT	NT	NT	0.00012	0.00001	
Methane (L/m <sup>3</sup> )		3L/m <sup>3</sup>	NR	12	NT	NT	NT	ND	0.02	
2-Methylisoborneol (MIB) (ng/L)		8.5	NR	Weekly as Required	ND	ND	ND	ND	3.0 ng/L	MIB is tested weekly from July 1-Oct 31. Results are expressed as the average per quarter when testing is required.
Nitrate	10.0		3	3	0.754	0.320	0.354	0.330	0.006	
Nitrite	1.0		3	3	ND	ND	ND	ND	0.003	
Organic Nitrogen		0.15	NR	12	NT	NT	NT	0.00009	0.05	Organic nitrogen is calculated by subtracting Total Ammonia from Total Kjeldahl Nitrogen
Sodium		200	60	12	NT	NT	NT	11.1	0.01	The local Medical Officer of Health must be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.
Sulphate		500	NR	12	NT	NT	NT	26	0.04	
Sulphide		0.05	NR	12	NT	NT	NT	ND	0.006	

General Chemistry or Physical Parameter	MAC or IMAC (mg/L)	Objective AO/OG (mg/L)	O.Reg. 170/03 Required Frequency of Testing (months)	Contractual Required Frequency of Testing (months)	Q2 2021	Q3 2021	Q4 2021	Q1 2022	Reportable Detection Limit (mg/L)	Comments
Toluene	0.06		NR	12	NT	NT	NT	ND	0.00036	
Total Dissolved Solids		500	NR	12	NT	NT	NT	120	30	
Trihalomethanes (Arva Reservoir)	0.100		3	3	0.023	0.025	0.031	0.018	0.00037	The standard is expressed as a running annual average of quarterly samples measured at a point reflecting the maximum residence time in the distribution system. Running annual average: 0.024 mg/L
Trihalomethanes (Exeter-Hensall)	0.100		3	3	0.034	0.037	0.047	0.029	0.00037	The standard is expressed as a running annual average of quarterly samples measured at a point reflecting the maximum residence time in the distribution system. Running annual average: 0.037mg/L
Trihalomethanes (Komoka-Mt. Brydges)	0.100		3	3	0.028	0.030	0.033	0.022	0.00037	The standard is expressed as a running annual average of quarterly samples measured at a point reflecting the maximum residence time in the distribution system. Running annual average: 0.028 mg/L

General Chemistry or Physical Parameter	MAC or IMAC (mg/L)	Objective AO/OG (mg/L)	O.Reg. 170/03 Required Frequency of Testing (months)	Contractual Required Frequency of Testing (months)	Q2 2021	Q3 2021	Q4 2021	Q1 2022	Reportable Detection Limit (mg/L)	Comments
Trihalomethanes (Strathroy-Caradoc)	0.100		3	3	0.027	0.027	0.036	0.020	0.00037	The standard is expressed as a running annual average of quarterly samples measured at a point reflecting the maximum residence time in the distribution system. Running annual average: 0.028 mg/L
Xylenes	0.09	0.02	NR	12	NT	NT	NT	ND	0.00043	
Zinc		5.0	NR	12	NT	NT	NT	ND	0.002	

<sup>i</sup> Indicator of adverse water quality

<sup>ii</sup> Indicator of adverse water quality

<sup>iii</sup> In addition to the analytical samples noted, free chlorine residual is measured on a continuous basis at the treatment facility using on-line instrumentation.

<sup>iv</sup> In addition to the analytical samples noted, turbidity is measured on a continuous basis at the treatment facility using on-line instrumentation.

<sup>v</sup> Turbidity is both regulated by the Province of Ontario, and specified in accordance with the operating agreement with the Contracted Operating Authority. The turbidity reported (6 daily grab samples) is taken from the plant treated water discharge, which is not explicitly regulated in Provincial Regulations. Provincial Standards recommend an aesthetic objective of 5 NTU within a distribution system, and Provincial Regulation specifies a maximum of 1 NTU on individual filter effluent. The contract with the Operating Authority specifies a maximum turbidity of 0.2 NTU on treated water discharge from the water treatment plant and 0.1 NTU on individual filter effluent. There is currently no standard for combined filter effluent.