

Energy Consumption and Greenhouse Gas Emissions Reporting - for 2020

Confirm consecutive 12-mth period (mth-yr to mth-yr)	Jan/2020 - Dec/2020
Sector	Municipal Service Board
Agency Sub-sector	Municipal
Organization Name	Elgin Area Primary Water Supply System Joint Board of Management
Operation Name	Elgin Area Water Treatment Plant
Operation Type	Facilities related to the treatment of water
Address	43665 Dexter Line
City	Central Elgin
Postal Code	N5L 1J4
Avg hrs/wk	168
Annual Flow (ML)	16,033.14
Electricity Quantity (kWh)	9,442,845
Natural Gas Quantity (Cubic Meters)	188,815
GHG Emissions (Kg)	597,280
Energy Intensity (ekWh/Mega Litre)	714.12
Comments	