



Annual Drinking Water Report
Drinking-Water Systems Regulation O. Reg. 170/03

Drinking-Water System Number:	210000871
Drinking-Water System Name:	Elgin Area Primary Water Supply System (EAPWSS)
Drinking-Water System Owner:	Elgin Area Primary Water Supply System Joint Board of Management
Drinking-Water System Operating Authority:	Ontario Clean Water Agency (OCWA)
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1, 2025 through December 31, 2025

<p>Complete if your Category is Large Municipal Residential or Small Municipal Residential</p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <p>Lake Huron and Elgin Area Water Supply Systems c/o Regional Water Supply Division 235 North Centre Road, Suite 200 London, ON N5X 4E7 https://huronelginwater.ca/</p> <p>Elgin Area Primary Water Supply System 43665 Dexter Line, Union, ON N0L 2L0</p>	<p>Complete for all other Categories.</p> <p>Number of Designated Facilities served: N/A</p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes <input type="checkbox"/> No <input type="checkbox"/></p> <p>Number of Interested Authorities you report to: N/A</p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes <input type="checkbox"/> No <input type="checkbox"/></p>
--	--



Annual Drinking Water Report
Drinking-Water Systems Regulation O. Reg. 170/03

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Systems that receive their drinking water directly from the EAPWSS:

Drinking Water System Name	Drinking Water System Number
City of London Distribution System	260004917
St. Thomas Area Secondary Water Supply System	260078897
Aylmer Area Secondary Water Supply System	260004722
Port Burwell Area Secondary Water Supply System	260004735
Central Elgin Distribution System	260004761
St. Thomas Distribution System	260002187

Systems that receive their drinking water indirectly from the EAPWSS:

Drinking Water System Name	Drinking Water System Number
Aylmer Distribution System	260002136
Malahide Distribution System	260004774
Dutton Dunwich Distribution System	220002967
Bayham Distribution System	260004748
Southwold Distribution System	210001362

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes No

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____



Annual Drinking Water Report
Drinking-Water Systems Regulation O. Reg. 170/03

Describe your Drinking-Water System

The Elgin Area Primary Water Supply System employs pre-chlorination, screening, process pH adjustment (utilizing carbon dioxide), powder activated carbon addition (seasonally on an as-required basis), coagulation, flocculation, sedimentation, dual-media filtration, UV disinfection, post-chlorination, final pH adjustment (utilizing sodium hydroxide) and fluoridation to treat raw water obtained from Lake Erie. The Water Treatment Plant (WTP) has a rated capacity of 91 ML/day (MLD). Water is pumped from the plant through the primary transmission main (900mm diameter) to various communities enroute to the Elgin Terminal Reservoir located in northeast St. Thomas. The drinking water system is monitored at various locations throughout the system via a Supervisory Control and Data Acquisition (SCADA) system.

A Residuals Management Facility (RMF) provides equalization, clarification, sediment thickening and dechlorination. Thickened sediment is dewatered by centrifuges and the thickened sediment is sent to the landfill for final disposal. Clarified and dechlorinated liquid streams are discharged back to Lake Erie through the plant drain.

List all water treatment chemicals used over this reporting period

- Carbon Dioxide
- Aluminum Sulphate
- Cationic Polymer
- Powder Activated Carbon (PAC)
- Chlorine Gas
- Hydrofluorosilicic Acid
- Sodium Hydroxide
- Dewatering Polymer (Residuals Management Facility)
- Thickening Polymer (Residuals Management Facility)
- Sodium Bisulphite (Residuals Management Facility)
- Calcium Thiosulfate (Residuals Management Facility)

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment



Annual Drinking Water Report

Drinking-Water Systems Regulation O. Reg. 170/03

Please provide a brief description and a breakdown of monetary expenses incurred:

Capital and Maintenance Projects:

- Overhead Door replacement (High Lift Garage)
- Low Lift Instrumentation Panel replacement
- Roof drain replacements (Chlorine and Flocculation Buildings)
- Treated Water sample line replacement
- Low Lift Pump Discharge Valve replacements
- Low Lift Distribution Well chlorine injection upgrades
- Fruitridge Surge Facility safety upgrades (ladder, roof vent, fall arrest system)
- Technical Standards & Safety Authority (TSSA) generator fuel system upgrades
- Backwash Pump #1 and #2 Discharge Valve Body replacements
- Elgin Terminal Reservoir Cell #1 Access Ladder replacement
- Lab Equipment installation (Benchtop Zeta Potential analyzer)
- Forklift Load Scale installation
- Programmable Logic Controller (PLC) replacements project – including SCADA Control Panel upgrade (High Lift SCP09)
- Particle Counter replacements (Treated and Filtered water)
- RMF Total Chlorine analyzer installation
- Ultraviolet (UV) Disinfection System & Backwash Pump replacement project
- Server room fire suppression system installation
- Security upgrades (WTP fencing, remote station gate automation, intercom, card access and cameras)
- Sodium hydroxide system upgrades (new injection quills)
- IT Asset Replacement Program
- Low Lift Sluice Gate #1 upgrades

Studies and Design:

- Biofilter Research Project electrical upgrades
- Elgin Terminal Reservoir Expansion – Preliminary engineering
- Elgin Terminal Reservoir Cell #1 & #2 Condition Assessment
- Elgin-Middlesex Pump Station (EMPS) Asset Management Plan Update
- Master Water Plan Update
- PAC Dosing Strategy Optimization
- RMF Tank Mixing Study



Annual Drinking Water Report
Drinking-Water Systems Regulation O. Reg. 170/03

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Report Date	Parameter	Corrective Action	Corrective Action Date
October 27, 2025	Chemical - Fluoride	Adverse Water Quality Incident (AWQI) reported (ref# 170559) for a treated water fluoride grab sample result over 1.50 mg/L on October 27, 2025. During a routine high lift pump change, there was an initial fluoride spike over 1.50 mg/L interlocking the high lift pumps. When the high lift pumps were restarted, a second fluoride spike occurred. The EAPWSS has regulatory relief under the Municipal Drinking Water Licence 048-101 for continuous monitoring of fluoride and reporting adverse condition in which, the continuous monitoring met compliance. However, in response to the spike the operator obtained a grab sample result of 1.88 mg/L fluoride residual. This was reported as the AWQI. The system was flushed, preventing the elevated residual from entering the distribution system and the water treatment plant was returned to normal service.	November 4, 2025



Annual Drinking Water Report

Drinking-Water Systems Regulation O. Reg. 170/03

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

Location	Number of Samples	Range of E. coli Results (CFU/100 mL) (min #)-(max #)	Range of Total Coliform Results (CFU/100 mL) (min #)-(max #)	Range of HPC Results (CFU/100 mL) (min #)-(max #)
Raw Water	104	(0)-(300)	(0)-(12,900)	(<10)-(>2,000)
Treated Water (WTP)	216	(0)-(0)	(0)-(0)	(0)-(1,810)
Distribution (Elgin Terminal Reservoir Valve House)	104	(0)-(0)	(0)-(0)	(<10)-(350)
Distribution (Fruitridge Surge Facility)	53	(0)-(0)	(0)-(0)	(<10)-(550)

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

Parameter	Number of Samples	Range of Results (min #)-(max #)
Treated Water Free Chlorine (mg/L)	Continuous Monitoring	(0.09)-(2.23)*
Treated Water Fluoride (mg/L)	Continuous Monitoring	(0.08)-(1.95)**
Filter #1 - Filtered Water Turbidity (NTU)	Continuous Monitoring	(0.022)-(0.418)
Filter #2 - Filtered Water Turbidity (NTU)	Continuous Monitoring	(0.024)-(0.422)
Filter #3 - Filtered Water Turbidity (NTU)	Continuous Monitoring	(0.016)-(0.396)
Filter #4 - Filtered Water Turbidity (NTU)	Continuous Monitoring	(0.012)-(0.357)
Raw Water Turbidity (NTU)	Continuous Monitoring	(0)-(1,000)
Elgin Terminal Reservoir Inlet Free Chlorine (mg/L)	Continuous Monitoring	(0.60)-(1.48)

Monthly filter performance met for all four filters (<0.3NTU 95% of the readings).

*Treated water free chlorine residual met requirements for primary disinfection.

**There was no Adverse Water Quality Incident (AWQI) reported for continuous monitoring due to regulatory relief in the Municipal Drinking Water Licence 048-101. However, AWQI #170559 was reported on October 27, 2025 for a fluoride grab sample over 1.50 mg/L. Details provided above.



Annual Drinking Water Report

Drinking-Water Systems Regulation O. Reg. 170/03

Summary of Inorganic parameters tested during this reporting period

(*All tests were conducted on treated water leaving the WTP unless otherwise noted)

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Arsenic	January 7, 2025 August 5, 2025	0.0003 0.0004	mg/L	NO
Barium	January 7, 2025 August 5, 2025	0.0216 0.0193	mg/L	NO
Boron	January 7, 2025 August 5, 2025	0.017 0.020	mg/L	NO
Cadmium	January 7, 2025 August 5, 2025	0.000006 0.000003	mg/L	NO
Chromium	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Lead (Elgin Terminal Reservoir Valve House)	January 7, 2025 July 2, 2025 October 7, 2025	0.00002 Not Detected Not Detected	mg/L	NO
Mercury	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Selenium	January 7, 2025 August 5, 2025	0.00015 0.00020	mg/L	NO
Uranium	January 7, 2025 August 5, 2025	0.000074 0.000056	mg/L	NO
Sodium	January 7, 2025	8.53	mg/L	NO
Nitrite	January 7, 2025 April 1, 2025 July 2, 2025 October 7, 2025	Not Detected Not Detected Not Detected Not Detected	mg/L	NO
Nitrate	January 7, 2025 April 1, 2025 July 2, 2025 October 7, 2025	0.180 0.162 0.029 0.031	mg/L	NO



Annual Drinking Water Report

Drinking-Water Systems Regulation O. Reg. 170/03

Summary of Organic parameters sampled during this reporting period

(*All tests were conducted on treated water leaving the WTP unless otherwise noted)

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Atrazine + N-dealkylated metabolites	January 7, 2025 August 5, 2025	0.00005 0.00002	mg/L	NO
Azinphos-methyl	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Benzene	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Benzo(a)pyrene	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Bromoxynil	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Carbaryl	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Carbofuran	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Carbon Tetrachloride	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Chlorpyrifos	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Diazinon	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Dicamba	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
1,2-Dichlorobenzene	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
1,4-Dichlorobenzene	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
1,2-Dichloroethane	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
1,1-Dichloroethylene (vinylidene chloride)	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO



Ontario
Annual Drinking Water Report
 Drinking-Water Systems Regulation O. Reg. 170/03

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Dichloromethane	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
2,4-Dichlorophenol	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
2,4-Dichlorophenoxy acetic acid (2,4-D)	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Diclofop-methyl	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Dimethoate	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Diquat	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Diuron	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Glyphosate	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Haloacetic Acids (HAA's) Elgin Terminal Reservoir Valve House	January 7, 2025 April 1, 2025 July 2, 2025 October 7, 2025	Not Detected Not Detected Not Detected 0.0059	mg/L	NO
Haloacetic Acids (HAA's) Elgin Terminal Reservoir Valve House = Running Annual Average	2025	<0.0053	mg/L	NO
Malathion	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
2-Methyl-4-chlorophenoxyacetic acid	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Metolachlor	January 7, 2025 August 5, 2025	0.00001 Not Detected	mg/L	NO
Metribuzin	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Monochlorobenzene	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Paraquat	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO



Annual Drinking Water Report

Drinking-Water Systems Regulation O. Reg. 170/03

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Pentachlorophenol	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Phorate	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Picloram	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Polychlorinated Biphenyls (PCB)	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Prometryne	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Simazine	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Total Trihalomethanes (THMs) Elgin Terminal Reservoir Valve House	January 7, 2025 April 1, 2025 July 2, 2025 October 7, 2025	0.012 0.010 0.016 0.020	mg/L	NO
(THMs) Elgin Terminal Reservoir = Running Annual Average	2025	0.015	mg/L	NO
Terbufos	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Tetrachloroethylene	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
2,3,4,6-Tetrachlorophenol	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Triallate	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Trichloroethylene	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
2,4,6-Trichlorophenol	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Trifluralin	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO
Vinyl Chloride	January 7, 2025 August 5, 2025	Not Detected Not Detected	mg/L	NO

NOTE: During 2025, no Inorganic or Organic parameter(s) exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.



Ontario
Annual Drinking Water Report
 Drinking-Water Systems Regulation O. Reg. 170/03

Summary of Additional Legislative Sampling during this reporting period

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Microcystin (Raw Water)	May 27, 2025 to December 3, 2025	<0.1 to 0.1*	ug/L	No
Microcystin (Treated Water)	May 27, 2025 to December 3, 2025	All results <0.1	ug/L	No
RMF Total Suspended Solids (Effluent Discharge)	January 1, 2025 to December 31, 2025 (Monthly Average)	4.00 to 7.23	mg/L	No
RMF Total Chlorine Residual (Effluent Discharge)	January 1, 2025 to December 31, 2025 (Monthly Average)	0.00	mg/L	No
UV #1 Dose	January 1, 2025 to December 31, 2025	0.0** to 653.7	mJ/cm ²	No
UV #2 Dose	January 1, 2025 to December 31, 2025	0.0** to 654.3	mJ/cm ²	No
UV #3 Dose	January 1, 2025 to December 31, 2025	0.0** to 654.0	mJ/cm ²	No
UV #4 Dose	January 1, 2025 to December 31, 2025	0.0** to 653.4	mJ/cm ²	No

*Detectable result of microcystin in raw water reported to Ministry of the Environment, Conservation and Parks (MECP) in accordance with Harmful Algal Bloom Plan. Microcystin was non-detectable in the treated water.

** Primary disinfection was achieved for all instances where UV dose dropped below 40 mJ/cm². Refer to 2025 Annual Compliance Report (Schedule 22).